No: PHI/Water/BAC/347/2026-27. **GOVERNMENT OF KARNATAKA**

Office of Joint Director
Public Health Institute,
Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date : 02/07/2026

To
National Public School, K.R.Puram
S.No 72/1, Hisavanda-halli (V) Bidarahalli Hobli, Virgonagar. Post Bidare-49

Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
		Opinion					
1047	RO outlet water	Nil	—	—	SPP	—	—

Note:
M.P.N. Count:
Most Potable number of Bacteria Per 100ml of Water
D.C Test:
Differential Coliform test
Plate Count:
Plate Count per ml of sample
SPP:
Water is satisfactory for Potable purpose
NSPP:
Water is not satisfactory for Drinking purpose
NSPP & FC:
Water is not satisfactory for Drinking purpose and E. Coli found

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

Microbiologist
(Senior Specialist)
Public Health Institute
Bangalore - 560 001